Installation Guidance

700 timed basin tap

B&M SKU ID700.B4/1 | Idral code 700.B4/1

Installation sequence

1. Have a qualified installer prepare the supply connections using the original model drawing. Purge the pipes before connection and provide suitable water filtration.

2. Prepare the wall housing to suit the concealed box. Route the supply and outlet connections using ISTA35-02 Figures 01–02, then align and secure the box using the included spirit levels.

3. Connect the pipes securely and protect the assembly during masonry work. On completion, trim the protective cover and fit the internal fittings and tap body as shown in Figure 03.

4. Fit the protective plate, cover plate, control and spout using Figures 04–06. Retain access to service components.

5. Open the supply and check all connections for leaks. Test the push button and automatic closure.

6. The current Technical Specification gives 15 ± 5 seconds at 3 bar, while the shared manual gives approximately 25 seconds. Confirm the installed cartridge and actual cycle before commissioning.

Important

Installation pressure: 1–5 bar (recommended 2–4 bar); water temperature 5–65 °C. Protect the valve from freezing.

The shared installation manual has a narrower pressure range than the product Technical Specification; this guidance uses the manual limit.

Source: Idral ISTA35-02. This summary accompanies the original manufacturer instructions supplied separately. Read the original instructions for complete safety information, model diagrams and service procedures.